

CERTIFICATE OF COMPLIANCE

Certificate Number 20150424-E474139
Report Reference E474139-20150424
Issue Date 2015-APRIL-24

Issued to: ELECTRI-CORD MFG CO INC
312 E MAIN ST
PO BOX 167
WESTFIELD PA 16950-0167

**This is to certify that
representative samples of**

CONTROL PANELS AND ASSEMBLIES FOR USE IN
HAZARDOUS LOCATIONS

USL, CNL Industrial Control Panels For Use In Class I,
Division 1, Groups A, B, C and D Hazardous Locations,
Type X Purge.

May be provided with intrinsically safe circuit extensions for
use in Class I, Groups A, B, C and D; Class II, Groups E, F,
G Hazardous Locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


NFPA 496, Purged and Pressurized Enclosures for
Electrical Equipment
UL 698A, Industrial Control Panels Relating to Hazardous
(Classified) Locations
CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-
incendive Equipment for Use in Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

